



Rapport d'inspection périodique Sécurité Générale du Bâtiment 3595

Exécutée par: LONJON, Pauline

Date visite: 27-04-2017

Date validité: 27-04-2019



Informations générales du bâtiment

Département	EP	Classement	Medium
DSO	BELTRAMELLO, Olga	Localisation	L5
DDSO	DUPONT, Niels Aurelien	Type	BAT
ADSO	POIROT, Johann Alain DHO, Evelyne DI GIULIO, Letizia UGIDOS SEMAN, Saray VIGNES-MAGNO, Antonella MAIRE, Gilles MARDIROSSIAN, Isabelle NIKOLICS, Katalin DESMAREST, Alexandre	Surface	757.3
TSO	ROEDNE, Lars Tore	Nombre de niveaux	3
DTSO	MEYNET CORDONNIER, Alain	Spécialistes	-
GLIMOS	-		
DGLIMOS	-		
RPO	TROMEL, Christophe		

Liste de diffusion

BELTRAMELLO, Olga	POIROT, Johann Alain
DHO, Evelyne	DUPONT, Niels Aurelien
MEYNET CORDONNIER, Alain	ROEDNE, Lars Tore
DI GIULIO, Letizia	UGIDOS SEMAN, Saray
VIGNES-MAGNO, Antonella	MAIRE, Gilles
MARDIROSSIAN, Isabelle	NIKOLICS, Katalin
ZEUNER, Wolfram Dietrich	DESMAREST, Alexandre
LONJON, Pauline	

But de l'inspection

Le CERN, procède à des inspections de sécurité initiales et périodiques de ses infrastructures conformément aux règles de sécurité en vigueur. Le terme générique infrastructure désigne un bâtiment, une installation, un appareillage d'expérimentation ou un équipement devant faire l'objet d'inspections régulières.

Dans les bâtiments, les inspections de sécurité permettent d'évaluer les conditions générales de sécurité et de travail. Elles peuvent mettre en évidence des mesures à prendre ou des modifications à apporter afin d'améliorer la sécurité ou les conditions de travail.

Les inspections de sécurité périodiques vérifient que la sécurité d'une infrastructure est toujours assurée au niveau défini par son inspection de sécurité initiale et conformément aux règles de sécurité en vigueur.

Lien vers les règles de sécurité: <https://www.cern.ch/regles-securite>

Lien vers Sailor Light: <https://cern.ch/service-sailorlight>

Lien vers le rapport EDMS et les ancien rapport:

<https://edms.cern.ch/document/1802500/1>

https://edms.cern.ch/asbuilt/plsql/mtf_location.loc_main_top?p_rec_type=L&p_rec_id=3595

Domaines de sécurité du bâtiment

Domaines	Présents	Non maîtrisés	Domaines	Présents	Non maîtrisés
Autres			Chantier		
Environnement			Ergonomie		
Lieu de travail	X	X	Sécurité Cryogénique		
Sécurité biologique	X	X	Sécurité chimique	X	X
Sécurité des rayonnements ionisants			Sécurité des rayonnements non-ionisants		
Sécurité des structures			Sécurité incendie	X	X
Sécurité mécanique			Sécurité électrique et électromagnétique	X	X
Urgence					

Synthèse du rapport

Type de remarques	Nombre de remarques	Conclusion de l'inspection
Priorité 1	2	
Priorité 2	7	
Priorité 3	6	
Information	2	Le bâtiment reste classé en niveau de risque moyen, par conséquent, la prochaine inspection de sécurité générale aura lieu dans deux ans à compter de cette date.

Documents associés



--



Priorité(s) 1

Local + resolver	Remarque	Statut
Sécurité chimique		
1 Local [R/012] Resolver(s) : MEYNET CORDONNIER, Alain ROEDNE, Lars Tore	<p>Sécurité chimique - Chimie Chemical products are stored in water bottles. The use of food containers for storage of chemical products is forbidden to avoid any risk of confusion and intoxication. Eliminate the food containers as waste. Use adapted containers and copy the label of the original packaging or put a regulatory labeling as specified in the good practices sheet EDMS : 1029740. https://edms.cern.ch/document/1029740/3</p>	Distributed

Photo:



Sécurité biologique

Local + resolver	Remarque	Statut
Sécurité biologique		
2 Local [1/010] Resolver(s) : ZEUNER, Wolfram Dietrich DUPONT, Niels Aurelien	<p>Sécurité biologique - Tabac It is possible that some people smoke in the building. Smoking is forbidden in buildings according to the safety rules SR-S, EDMS 889075. https://edms.cern.ch/document/889075/1 The use of tobacco is forbidden in CERN. Remind the rules to these people.</p>	Distributed

Photo:



Priorité(s) 2

Local + resolver	Remarque	Statut
Sécurité incendie		

3 Sécurité incendie - Incendie
- Presence of equipment with a high heat potential. Evacuate all unnecessary storage and limitate the quantity of these objects to the bare essentials for work.
R/002; R/008; R/011;R/010 Action to transmit to users

Distributed

Resolver(s) :

MEYNET CORDONNIER, Alain
ROEDNE, Lars Tore

Photo:





Sécurité chimique

4	Sécurité chimique - Chimie	Distributed
Local [R/006]	Chemical products are stored in a room where there are fridges, microwaves and water. Gather these products in a metallic, ventilated cabinet along with the FDS (security data sheets), respecting the compatibility rules of chemical products' storage. Identify the storage cabinets of chemical products (SCEM 50.55.20). Put liquid products on a containment bund. The containment bunds are available at CERN stores for cabinets with a 45 cm depth (SCEM : 55.50.71.020.0), (SCEM 55.50.71.030.0) for lower depth, flammable products excluded. For capacity, contact J.Gulley (HSE/SEE 78526 - 160890). For all information, consult the good practices sheet EDMS 1029740. https://edms.cern.ch/document/1029740/3	
Resolver(s) :	MEYNET CORDONNIER, Alain ROEDNE, Lars Tore	

Photo:



5	Sécurité chimique - Chimie	Distributed
Local [1/011]	Containers with chemical products are not identified. To eliminate any risk of confusion put a regulatory labeling indicating the name of the product. If possible copy the label of the original packaging, the label can be provided by the stores at the order of the product. Concerning the labeling of wash bottles, there are pre-printed wash bottles available at CERN stores (SCEM 19.19.35). For all information, consult the good practices sheet EDMS 1029740. https://edms.cern.ch/document/1029740/3	
Resolver(s) :	MEYNET CORDONNIER, Alain ROEDNE, Lars Tore	

Photo:



Sécurité biologique

6	Sécurité biologique - Hygiène	Distributed
Local [1/010]	For information, presence of 2 microwaves and 1 fridge in good condition in a room dedicated to catering.	
Resolver(s) :	Make sure to meet the requirements of document EDMS 1083739.	
ZEUNER, Wolfram Dietrich	For more information, consult the improvement sheet EDMS 890714.	
DUPONT, Niels Aurelien		

Photo:



Lieu de travail

7	Lieu de travail - Chutes d'objets	Distributed
Local [1/102]	Un néon menace de tomber. Le refixer afin de supprimer le risque de chute.	
Resolver(s) :		
General Services(GS/SE)	Photo:	

**HSE**Occupational Health & Safety
and Environmental Protection Unit

8	Lieu de travail	Distributed
Local [1/101]	Présence d'un trou dans le mur. Le reboucher afin d'éviter toute infiltration d'eau.	

Resolver(s) :
General Services(GS/SE)

Photo:

Sécurité électrique et électromagnétique

9	Sécurité électrique et électromagnétique - Electricité	Distributed
Building	Following the distribution of the EDMS electrical report n° 1706320 v.1, process the observations and/or contact the concerned services to solve them.	

Resolver(s) :
MEYNET CORDONNIER, Alain
ROEDNE, Lars Tore

Priorité(s) 3

Local + resolver	Remarque	Statut

Sécurité incendie

10	Sécurité incendie - Incendie	Distributed
Local [R/009]	Presence of a leather couch which is degraded. Remove it in order to limit the fire risk. For information, leather furniture is tolerated provided that it doesn't present any visible damage. for more information, contact F. Corsanego (HSE/SEE-79973/164548) or S. La Mendola (HSE/SEE-168960).	
Resolver(s) : MEYNET CORDONNIER, Alain ROEDNE, Lars Tore	Photo:	



Lieu de travail

11	Lieu de travail - Chutes d'objets	Distributed
-	Heavy, protruding or inappropriate objects are stored in height and can cause injuries in case of falling, especially when people try to reach the stored pieces. Reorganize the storage space to eliminate the storage in height and this way eliminate any risk of falling.	
R/005; R/010; R/011; R/012; R/016; 1/011	Action to transmit to users	

Resolver(s) :

MEYNET CORDONNIER, Alain
ROEDNE, Lars Tore

Photo:







Sécurité biologique

12

Local [1/002]

Sécurité biologique - Hygiène

Distributed

Presence of 2 fridges and a microwave in bad condition. Clean it or evacuate it.

Action to transmit to users

Resolver(s) :

MEYNET CORDONNIER, Alain
ROEDNE, Lars Tore

Photo:



13

Local [R/011]

Sécurité biologique - Hygiène

Distributed

Presence of a fridge in bad condition. Clean it or evacuate it.

Action to transmit to users

Resolver(s) :

MEYNET CORDONNIER, Alain
ROEDNE, Lars Tore

Photo:



14 Sécurité biologique - Hygiène Distributed
Local [R/006] Presence of a microwave in bad condition. Clean it or evacuate it.
Action to transmit to users

Resolver(s) :

MEYNET CORDONNIER, Alain
ROEDNE, Lars Tore

Photo:



Lieu de travail

15 Lieu de travail - Accès Distributed
Local [1/010] Le local n'est pas identifié. Mettre en place le numéro sur les portes du local.

Resolver(s) :

General Services(GS/SE)

Photo:





Information(s)

Local	Information	
Lieu de travail		
Building	Type: Lieu de travail For information , presence of fridges and microwaves in the building : R/006 : 1 fridge in good condition + 1 microwave in bad condition R/009 : 1 fridge in good condition + 1 microwave in good condition R/011 : 1 fridge in bad condition 1/010 : 1 fridge in good condition + 2 microwaves in good condition in a room dedicated to catering 1/011: 1 fridge in good condition + 1 microwave in good condition 1/101 : 1 microwave in good condition 1/005 : 3 fridges in good condition 1/002 : 2 fridges in bad condition + 1 microwave in bad condition	
Lieu de travail		
Building	Type: Lieu de travail - Accès For information, a campaign to update the TSO labels will take place this summer at point 5.	