

ZEC Service 2015 - pressure test's ; leak test's ; or leak repair

date	where	system	wheel / disk	patch panel number	sector	Delta T [hour]		Delta P [Bar]		kind of intervention	name
						time start	time end	P start	P end		
22.1.2015	USC55 - 1	Cooling	rack cooling modifs		S2B08	10.00	11.00	10.03	10.05	pressure test with water	Leszek & Ryszard
	Francesca & Wolfgang										
28.01.2016	UXC-4E+1/ME+1	~"~	manifold - ME+1			8 ³⁰	9 ³⁵	12,36	12,34	WATEV.	Ryszard - Wiesław Bogdan
						9 ³⁵	11 ²⁵	15,11	15,09	~"~	
						13 ³⁰	16 ⁴⁰	15,05	15,00	~"~	
03.02.2016	UXC-4E+3/RE+4 FAR	~"~	4E+3/RE+4/3 + mini manifold.		21-26	8 ³⁰	9 ⁵⁰	11,94	11,93	~"~	Ryszard - Wiesław Bogdan
						10 ⁰⁰	11 ⁰⁰	18,20	18,18	~"~	
04.02.2016	UXC-4E+3/ FAR.	~"~	4E+3/RE+4/3 + mini manifold		15-20	13 ⁴⁵	14 ³⁰	12,21	12,27	~"~	Ryszard - Wiesław Bogdan
						15 ⁰⁵	16 ³⁰	18,25	18,24	~"~	
04.02.2016	UXC-4E+3 NAR	~"~	4E+3/RE+4/3 + mini manifold		27-32	14 ²⁰	15 ³⁰	12,25	12,23	~"~	Ryszard - Wiesław Bogdan
05.02.2016	~"~	~"~	~"~		~"~	9 ³⁰	10 ³⁰	18,18	18,14	~"~	Ryszard - Wiesław Bogdan
05.02.2016	UXC-4E+3 NAR	~"~	4E+3/RE+4/3 + mini manifold		02-33	11 ⁴⁵	13 ²⁰	12,09	12,07	~"~	Ryszard - Wiesław Bogdan
						14 ²⁰	16 ³⁰	18,22	18,20	~"~	
05.02.2016	UXC-4E+3 FAR.	~"~	4E+3/RE+4/3 + mini manifold		09-14	14 ⁴⁵	15 ²⁵	12,25	12,30	~"~	Ryszard - Wiesław Bogdan
						15,45	16 ⁴⁵	18,31	18,35	~"~	
08.02.2016	UXC-4E+3 NAR	~"~	4E+3/RE+4/3 + mini manifold		03-08	12 ¹⁵	13 ⁴⁰	12,14	12,12	~"~	Ryszard - Wiesław Bogdan
						13 ⁵⁵	15 ⁰⁵	18,26	18,26	~"~	